



BITZER COMPRESSORES LTDA.
RELATÓRIO DE TESTES

RT 191/99

Ref.: Resistência Ôhmica do Pt 1000 x Temperatura

Temp. °C	Resist. Ω	Temp. °C	Resist. Ω	Temp. °C	Resist. Ω	Temp. °C	Resist. Ω
20	1074	54	1201	88	1337	122	1470
21	1078	55	1204	89	1341	123	1474
22	1082	56	1208	90	1345	124	1478
23	1085	57	1212	91	1349	125	1482
24	1088	58	1217	92	1354	126	1485
25	1091	59	1222	93	1357	127	1488
26	1094	60	1227	94	1362	128	1493
27	1097	61	1231	95	1366	129	1497
28	1100	62	1235	96	1368	130	1501
29	1103	63	1240	97	1372	131	1505
30	1107	64	1244	98	1377	132	1509
31	1100	65	1248	99	1381	133	1514
32	1113	66	1252	100	1384	134	1518
33	1118	67	1256	101	1388	135	1522
34	1124	68	1259	102	1393	136	1527
35	1129	69	1263	103	1397	137	1531
36	1132	70	1267	104	1400	138	1535
37	1135	71	1271	105	1403	139	1538
38	1138	72	1275	106	1407	140	1543
39	1142	73	1279	107	1410	141	1547
40	1146	74	1283	108	1413	142	1551
41	1150	75	1286	109	1418	143	1555
42	1154	76	1289	110	1422	144	1559
43	1158	77	1294	111	1426	145	1563
44	1162	78	1299	112	1430	146	1567
45	1165	79	1302	113	1433	147	1571
46	1169	80	1306	114	1437	148	1575
47	1173	81	1310	115	1440	149	1579
48	1177	82	1314	116	1444	150	1584
49	1181	83	1319	117	1448		
50	1185	84	1322	118	1453		
51	1189	85	1326	119	1457		
52	1193	86	1330	120	1461		
53	1197	87	1333	121	1465		